



## BUTT END CAP

PRODUCED TO ASTM D2513 and D3261  
and AWWA C901-02 & C906-99

Butt End Cap	DR/Wall	Dimension L (in)	Package Quantity	Package Weight (lbs.)	Box Quantity	CSA <sup>1</sup>	IAPMO <sup>1</sup>	FM		Reference Number
								150	200	
1/2" CTS	0.090 wall	2.00	10	0.2	200	x				*M.50*CPST*
3/4" CTS	0.090 wall	2.30	10	0.2	100					*M.75*CPST*
1" CTS	0.102 wall	2.30	10	0.3	100					*M010*CPST*
	0.125 wall									
1/2" IPS	DR 9.3	2.20	10	0.2	100					*M.50*CPST*
3/4" IPS	DR 11	2.30	10	0.3		x				*M.75*CPST*
1" IPS	DR 9	2.40	10	0.5	50	x	x			*M010*CPST*
	DR 11									
1 1/4" IPS	DR 9	3.31	10	1.2	50	x				*M1.25*CPST*
	DR 10	3.94								
	DR 11									
1 1/2" IPS	DR 11	3.70	10	1.3	50	x				*M1.50*CPST*
2" IPS	DR 7	4.25	10	3.2	40	x		x	x	*M020*CPST*
	DR 9			2.6						
	DR 11									
	DR 17									
3" IPS	DR 7	4.80	10	10.0	10	x <sup>2</sup>	x	x	x	*M030*CPST*
	DR 9	3.94		8.1						
	DR 11 / 11.5			5.6						
	DR 13.5									
	DR 17									
4" IPS	DR 7	8.50	10	23.7	10	x <sup>2</sup>	x	x	x	*M040*CPST*
	DR 9	4.25		9.0						
	DR 11 / 11.5									
	DR 13.5									
	DR 17									
6" IPS	DR 7	9.88	6	27.9	6				x	*M060*CPST*
	DR 9	5.20	5	14.1	5	x <sup>2</sup>	x	x		
	DR 11 / 11.5									
	DR 13.5									
	DR 17									
8" IPS	DR 7	5.00	1	5.6		x		x	x	*M080*CPST*
	DR 9			4.3						
	DR 11									
	DR 13.5									
	DR 17									

<sup>1</sup> - CSA and IAPMO available as DriscoPlex<sup>®</sup> 6500 MDPE materials ONLY.

<sup>2</sup> - CSA only DR11 is approved (not 11.5)

x - Indicates certification/approval for application or test at additional charge.

- Drawing Nos. CU70B248 for 1/2" CTS thru 1" IPS

- Drawing Nos. CU70B258 for 1-1/4" thru 8" IPS